

7 January 2013

**ATTENTION: KATE MACDONALD**

Ms Heather Warton  
Director, Metropolitan & Regional Projects North  
Department of Planning & Infrastructure  
GPO Box 39  
SYDNEY NSW 2001

**MP11\_002 – Residential Buildings R8 & R9, Block X, Barangaroo South**

Dear Ms Warton,

Thank you for your letter 19 November 2012 requesting comment on the proposed residential development at Barangaroo South. Sydney Water has reviewed the proposal and provides the following comments for the Department's consideration.

Water and wastewater servicing for residential buildings R8 and R9 should be consistent with the yet to be approved Site Servicing Strategy for Barangaroo South.

**Sydney Water Servicing**

Sydney Water will further assess the impact of any subsequent development when the developer applies for a Section 73 Certificate. This assessment will enable Sydney Water to specify any works required as a result of future development and to assess if amplification and/or changes to the system are applicable. The developer must fund any adjustments needed to Sydney Water infrastructure as a result of the development.

The developer should engage a Water Servicing Coordinator to get a Section 73 Certificate and manage the servicing aspects of the development. The Water Servicing Coordinator will ensure submitted infrastructure designs are sized and configured according to the Water Supply Code of Australia (Sydney Water Edition WSA 03-2002) and the Sewerage Code of Australia (Sydney Water Edition WSA 02-2002).

Sydney Water requests the Council to continue to instruct proponents to obtain a Section 73 Certificate from Sydney Water. Details are available from any Sydney Water Customer Centre on 13 20 92 or Sydney Water's website at [www.sydneywater.com.au](http://www.sydneywater.com.au).

**Sydney Water e-planning**

Sydney Water has created a new email address for planning authorities to use to submit statutory or strategic planning documents for review. This email address is [urbangrowth@sydneywater.com.au](mailto:urbangrowth@sydneywater.com.au). The use of this email will help Sydney Water provide advice on planning projects faster, in line with current planning reforms. It will also reduce the amount of printed material being produced. This email should be used for:

- Section 62 consultations under the Environmental Planning and Assessment Act 1979
- consultations where Sydney Water is an adjoining land owner to a proposed development
- consultations and referrals required under any Environmental Planning Instrument
- draft LEPs, SEPPs or other planning controls, such as DCPs
- any proposed development or rezoning that will be impacted by the operation of a Sydney Water Wastewater Treatment Plant
- any proposed planning reforms or other general planning or development inquiries


Sydney Water Corporation ABN 49 776 225 038

1 Smith St Parramatta 2150 | PO Box 399 Parramatta 2124 | DX 14 Sydney | T 13 20 92 | [www.sydneywater.com.au](http://www.sydneywater.com.au)

Delivering essential and sustainable water services for the benefit of the community

If you require any further information, please contact Corrine Manyweathers of the Urban Growth Branch on 02 8849 4014 or e-mail [corrine.manyweathers@sydneywater.com.au](mailto:corrine.manyweathers@sydneywater.com.au).

Yours sincerely,

per.   
Adrian Miller,  
Manager, Growth Strategy