

MANAGING DIRECTORS

MATTHEW PALAVIDIS
VICTOR FATTORETTO

DIRECTORS

MATTHEW SHIELDS
BEN WHITE



7/08/2013

20130570.1/0708A/R0/TA

Karimbla Constructions Services (NSW) Pty Limited
Attn: Walter Gordon
Level 11
522-534 Kent Street
SYDNEY NSW 2000

14-18 Boondah Road, Warriewood- Child Care Acoustic Assessment

The letter presents proposed constructions for a boundary fence surrounding the child care centre to be located at 14 - 18 Boondah Road, Warriewood. It has been requested by the Department of Planning that a 1800mm boundary fence be installed on the western boundary of the site.

The following fence constructions would be acceptable:

- Lapped and capped timber fencing;
- Minimum 6mm thick fibrous cement sheet; or
- Minimum 0.48mm Colorbond sheet metal.

The western boundary fence should have no gaps between fencing sheets or between the base of the fence and the ground. Any and all penetrations should be sealed with a flexible sealant.

We trust this information is satisfactory. Please contact us should you have any further queries.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'Thomas Aubusson', is written over a light blue and white geometric background.

Thomas Aubusson

Acoustic Logic Consultancy Pty Ltd

SYDNEY MELBOURNE BRISBANE CANBERRA LONDON DUBAI SINGAPORE GREECE

T: (02) 8339 8000 | F: (02) 8338 8399 | 9 Sarah St MASCOT NSW 2020

www.acousticlogic.com.au

The information in this document is the property of Acoustic Logic Consultancy Pty Ltd ABN 11 068 954 343 and shall be returned on demand. It is issued on the condition that, except with our written permission, it must not be reproduced, copied or communicated to any other party nor be used for any purpose other than that stated in particular enquiry, order or contract with which it is issued.