



NOTES

1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ELECTRICAL SERVICES SECTION OF THE SPECIFICATION, THE ARCHITECTURAL DRAWINGS AND ALL OTHER RELEVANT SERVICES DRAWINGS.
2. ALL EQUIPMENT AND ACCESSORIES ARE NEW UNLESS NOTED OTHERWISE.
3. FINAL POSITION OF ALL EQUIPMENT TO BE DETERMINED ON SITE PRIOR TO INSTALLATION. REFER TO ARCHITECTURAL FITOUT DRAWINGS.
4. RATINGS AND TERMINATIONS OF ALL EQUIPMENT TO BE CONFIRMED WITH SUPPLIER/MANUFACTURER'S RECOMMENDATIONS PRIOR TO INSTALLATION.
5. THE LUMINAIRES ALONG THE PATHWAYS, ROADS AND ON THE BRIDGE, SERVE AS MARKER LIGHTS ONLY.
6. INSTALL PATHWAY LUMINAIRES ALONG THE PATHWAYS, AS SHOWN, AT APPROXIMATELY 8 METRE SPACING, BETWEEN LUMINAIRES. LUMINAIRES TO BE INSTALLED INTO THE ROAD SURFACE, LEVEL WITH THE ROAD, AIMING TOWARDS THE CENTRE LINE OF THE PATH. SUPPLY AND INSTALL POWER SUPPLY UNITS IN WEATHERPROOF ENCLOSURE. PROVIDE ONE POWER SUPPLY UNIT FOR MAXIMUM 6 LUMINAIRES.
7. RECESS BRIDGE LIGHTS INTO THE BRIDGE DECKING AS SHOWN. PROVIDE ONE POWER SUPPLY UNIT FOR MAXIMUM 6 LUMINAIRES. INSTALL TRANSFORMERS AND CABLES ON THE BRIDGE STRUCTURE.
8. WIRE POWER SUPPLY UNITS FOR PATHWAY LIGHTS AND BRIDGE LIGHTS TO THE LIGHTING CONTROL PANELS, AS SHOWN. LUMINAIRES TO BE CONTROLLED BY PHOTOELECTRIC CELL AND TIME SWITCH, WITH MANUAL OVERRIDE AT THE LIGHTING CONTROL PANELS.
9. CABLES FOR EXTERNAL LIGHTING SHALL GENERALLY BE DIRECTLY BURIED UNDERGROUND, IN COMMON TRENCH WITH POWER AND COMMUNICATIONS CABLES AND WITH OTHER SERVICES PIPES. MAINTAIN WITHIN THE TRENCH THE MINIMUM DISTANCES REQUIRED BY THE STANDARDS AND CODES, BETWEEN VARIOUS CABLES AND OTHER SERVICES PIPES. PROTECT CABLES IN CONDUIT UNDER ROADS AND PAVED AREAS AND WHERE INSTALLED ON THE BRIDGE.

PA	PRELIMINARY ISSUE	JRR	APP'D	--/--/06
REV.	DESCRIPTION	DRAWN	APP'D	DATE

Client

Emirates - Sydney
Level 9, 1 York Street
Sydney, NSW 2000
T 02 9290 9786
F 02 9299 9722



Project Manager

Clifton Coney Group Pty Ltd
Level 18, Citigroup Centre
Sydney, NSW 2000
T 02 9287 2100
F 02 9287 2188



Architect

TURNER+ASSOCIATES

LEVEL 1/586 CROWN STREET SURRY HILLS NSW 2010
T 02 9690 2855 F 02 9690 2411
NOMINATED ARCHITECT: Nicholas Turner 6695
DLQ QUALITY ENDORSED COMPANY ISO 9001:2000 LICENCE NUMBER 4168

Interior Designer

Chhada Siembieda
30 Boronia Street
Redfern, NSW 2016
T 02 9318 2627
F 02 9318 2151



Wood & Grieve Pty Ltd
A.C.N. 008 928 786
2/33 Ryde Road
PYMBLE NSW 2073
Phone 02 9484 7000
Fax 02 9484 7100
Email wge@wge.com.au
Web www.wge.com.au



PROJECT:
EMIRATES LUXURY RESORT
WOLGAN VALLEY
NEW SOUTH WALES

TITLE:
ELECTRICAL SERVICES
RESORT PRECINCT-SITE PLAN
EXTERIOR LIGHTING

PRELIMINARY
NOT FOR CONSTRUCTION

DESIGNED :	LVS	VERIFIED :	-	--/--/06
DRAWN :	JRR	APPROVED FOR TENDER :	-	--/--/06
SCALE :	1:1000	APPROVED FOR CONSTRUCTION :	-	--/--/06
CAD FILE:	18438-SYD-E/ELEC/E-04	1155	30/08/06	

DRAWING No. 18438-SYD-E-04	REVISION PA
--------------------------------------	-----------------------