

SMEC TESTING SERVICES Pty Ltd

Phone (02) 9756 2166, Fax (02) 9756 1137
E-Mail: smectesting@pacific.net.au

UNIT 14/1 COWPASTURE PLACE.

WETHERILL PARK, NSW 2164

DYNAMIC CONE PENETROMETER TEST REPORT

PROJECT: 72 - 73 WEST PARADE, WEST RYDE

REPORT No: 05/1753

CLIENT: RESITECH AUSTRALIA

REPORT DATE: 22-02-05

PROJECT No: 10530/1376B

SHEET 1 of 1

TEST METHOD: AS 1289.6.3.2

DATE TESTED: 18-02-05

TESTED BY: JK

SITE No:	P1	P2	P3	P4		
LOCATION:	Refer to Drawing No. 05/1753	Refer to Drawing No. 05/1753	Refer to Drawing No. 05/1753	Refer to Drawing No. 05/1753		
STARTING LEVEL	Surface Level	Surface Level	Surface Level	Surface Level		
DEPTH (m)	Penetration Resistance (blows / 150mm)					
0.00-0.15	2	*	2	2		
0.15-0.30	5	2	4	2		
0.30-0.45	11	5	5	3		
0.45-0.60	10	8	6	10		
0.60-0.75	10	10	9	22		
0.75-0.90	12	11	10	R		
0.90-1.05	14	14	12			
1.05-1.20	14	22	11			
1.20-1.35	18	R	18			
1.35-1.50	22		22			
1.50-1.65	R		R			
1.65-1.80						
1.80-1.95						
1.95-2.10						
2.10-2.25						
2.25-2.40						
2.40-2.55						
2.55-2.70						
2.70-2.85						
2.85-3.00						
3.00-3.15						
3.15-3.30						
3.30-3.45						
3.45-3.60						
3.60-3.75						

REMARKS: * Pre drilled prior to testing



NATA Accredited Laboratory
Number: 2750

The tests, calibrations or measurements covered by this document have been performed in accordance with NATA requirements which include the requirements of ISO/IEC 17025 and are traceable to Australian national standards of measurement. This document shall not be reproduced, except in full.

APPROVED SIGNATORY

Laurie Ihnativ - Manager