Barry Eadie Consulting Pty Ltd

50 Central Avenue Como West NSW 2226 • Ph: 02) 9528 7904 • Fax: 02) 9575 7756 • Mobile: 0432 739 443 ernail: barryeadie@optusnet.com.au • ABN: 61 111 815 215



5 December 2007

Rose Property Group 51 Riley St Wooloomooloo Attn: Nick Jackman

> Re: Catherine Hill Bay Gwandalan Concept Plan RFS response to bush fire issues Gwandalan

Dear Nick

Following receipt of correspondence from the NSW Rural Fire Service (RFS) dated 8 October 2007 , and the revised Concept Plan for the subject development I make the following comments in relation to bushfire matters.

The RFS correspondence states:

No dwelling entitlement is to be extended to proposed Lots 8 & 9. **NOTE: Asset Protection Zones** The required asset protection zone for proposed Lots 1 to 9 has been determined to be a minimum 25 metres. This is based on the vegetation algorithmetication as forest and a domain

minimum 25 metres. This is based on the vegetation classification as forest and a downslope of 5 degrees. The implementation of the required APZ would make accorded of the social Leteronical be for

The implementation of the required APZ would make several of the said Lots unviable for residential development.

Access

Public Road Access shall comply with section 4.1.3 (1) of Planning for Bush Fire Protection 2006.

In relation to the APZ the new Concept Plan, Issue B, has resulted in the Lots replacing the previous Lots 1 to 9 as being in the order of 50 metres in depth which will provide for the required APZ of 25 metres for all the proposed lots.

In relation to the Access provisions Planning for Bush Fire Protection 2006 section 4.1.3 (1) in general requires the following:

Urban perimeter roads are two-way, that is, at least two traffic lane widths (carriageway 8 metres minimum kerb to kerb). For non perimeter roads the road widths vary from 8.0 to 6.6 metres for curve radius from <40 to >100m inside radius.



Based upon the Concept Plan issue B and the traffic engineer comments the Concept Plan issue B would comply with both the APZ and Access requirements of the RFS.

A final bush fire assessment should be prepared for the subdivision project application.

If you have any questions or further information do not hesitate to contact me.

Yours truly,

13 Hade

Barry Eadie

5 December 2007 Version A Page 2 ۵