


CARDINAL FREEMAN VILLAGE

Supporting Documentation

Appendix Z

Energy Australia Correspondence

Prepared by **Jim Hatz & Associates**



61 2 92625982



Network Division

EnergyAustralia™**Facsimile**

To Jim Hatzlmanolis From John Menegus
At Jim Hatz & Associates Section Planning and Supply Negotiations
Network Division – Sydney South
cc Address 33 – 45 Judd Street, Oatley, 2223
Facsimile 9437 1020 Telephone 9585 5660 Fax 9585 5670
0408 66 1750

Total no. of pages 1 Date 06/07/2007 Email jmenegus@energy.com.au Internet www.energy.com.au

This facsimile is solely for the use of the intended recipient and may contain information which is confidential or privileged. Unauthorised use of its contents is prohibited. If you have received this facsimile in error, please notify the sender immediately via return facsimile and then destroy the original facsimile.

Jim,

In reply to your letter dated 28/6/07 regarding additional load at Cardinal Freeman Village Buildings A and B.

On 23/5/2006 we received an application by email for the same load increase for which you are making application. This application was submitted by Alan Skofic of SEMF. Energy Australia has also received applications from other consultants in respect to the site over the past 4 years. The most recent communication in respect of this site came from Mays Chalak of ITC Group.

Energy Australia has issued advise in reply to these applications which can be summarised as follows:

- There are numerous separate electrical supplies into the complex. These supplies are not from the same source of supply;
- The on site switchboards do not accurately reflect the sources and destinations of the supplies and loads;
- There are no single line diagrams available in case of an emergency so emergency personnel would have great difficulty identifying the source of supply to the individual buildings;
- Under emergency conditions, the Main Switchboards are inaccessible and/or not clearly identified;
- Serious consideration be given to the consolidation of the existing supplies; and
- Additional supply can then be taken from the newly consolidated supply.

Our advise in reply to your letter is the same as list in the above dot points.

If you have any questions please contact me on 9585 5660.

Regards

John Menegus
Engineer – Planning, West