

Contact: Neville Osborne  
Phone: 02-9228-6337  
Fax: (02) 9228 6355  
Email: [neville.osborne@planning.nsw.gov.au](mailto:neville.osborne@planning.nsw.gov.au)

Mr Mark Fogarty  
CEO Wind  
CBD Wind-CBD Adjungbilly Pty Ltd  
Suite 2, Level 2  
53 Cross Street  
DOUBLE BAY NSW 2028

Our ref.: 10/04937

Dear Mr Fogarty

**Subject: Director-General's Requirements for Adjungbilly Wind Farm (10\_0095)**

The Department has received your application for the above project.

I have attached a copy of the Director-General's Requirements (DGRs) for the preparation of an Environmental Assessment for the project. These requirements have been prepared in consultation with relevant government authorities. I have attached a copy of the government authorities' comments for your information. Please note, in particular, the requirements of the Department of Environment, Climate Change and Water, for an Eastern Bentwing Bat research programme. I have also enclosed a list of relevant guidelines that you may wish to refer to during the preparation of the Environmental Assessment.

The DGRs have been prepared based on the information you have provided to date. Please note that under section 75F(3) of the *Environmental Planning and Assessment Act 1979*, the Director-General may alter these requirements at any time. If you do not submit an Environmental Assessment for the project within 2 years, the DGRs will expire.

Prior to exhibiting the Environmental Assessment that you submit for the project, the Department will review the document to determine if it adequately addresses the DGRs. The Department may consult with other relevant government authorities in making this decision. Please provide 6 hard copies and 6 CD copies<sup>1</sup> of the Environmental Assessment to assist this review.

If the Director-General considers that the Environmental Assessment does not adequately address the DGRs, the Director-General may require you to revise the Environmental Assessment. Once the Director-General is satisfied that the DGRs have been adequately addressed, the Environmental Assessment will be made publicly available for at least 30 days.

If your project is likely to have a significant impact on matters of National Environmental Significance, it will require an approval under the Commonwealth *Environment Protection and Biodiversity Conservation Act 1999* (EPBC Act). This approval would be in addition to any approvals required under NSW legislation and it is your responsibility to contact the Department of the Environment, Water, Heritage and the Arts to determine if an approval

---


<sup>1</sup> File parts must be no greater than 5Mb each.



under the EPBC Act is required for your project (<http://www.environment.gov.au> or 6274 1111).

Your contact officer for this proposal, Neville Osborne, can be contacted on 02-9228-6337 or via email at [neville.osborne@planning.nsw.gov.au](mailto:neville.osborne@planning.nsw.gov.au). Please mark all correspondence regarding the proposal to the attention of the contact officer.

Yours sincerely,

A handwritten signature that appears to read 'Daniel' followed by a stylized flourish. To the right of the signature is the date '28/7/10'.

Daniel Keary  
Director  
**Infrastructure Projects**



## Director-General's Requirements

### Section 75F of the *Environmental Planning and Assessment Act 1979*

<b>Project</b>	Construction and operation of a wind farm with up to 26 turbines in two clusters (Adjungbilly and Stockdale). Associated infrastructure includes access tracks, local road infrastructure upgrades, underground electrical and communication network, aboveground connection between the Stockdale cluster and the substation, temporary concrete batching plant, possible obstacle lighting, control room/facilities building, and substation and connection to either the 132kV Wagga Wagga to Yass or the 132kV Burrinjuck to Tumut TransGrid transmission lines.
<b>Site</b>	Adjungbilly cluster - approximately 26 km east of Gundagai and about 30 km north east of Tumut; and Stockdale cluster – approximately 22 north east of Gundagai and 17.5 km south of Jugiong, in the Gundagai local government area.
<b>Proponent</b>	CBD Wind-CBD Adjungbilly Pty Ltd
<b>Date of Issue</b>	28 <sup>th</sup> July 2010
<b>Date of Expiration</b>	28 <sup>th</sup> July 2012
<b>General Requirements</b>	<p>The Environmental Assessment (EA) must include:</p> <ul style="list-style-type: none"> <li>• an <b>executive summary</b>;</li> <li>• a <b>detailed description</b> of the project for both the wind farm and transmission line including: <ul style="list-style-type: none"> <li>→ construction, operation and decommissioning details;</li> <li>→ the location and dimensions of all project components including the wind turbines (including map coordinates and AHD heights), underground cabling between turbines, aboveground line linking the Stockdale cluster to the substation, electrical substation and transmission line linking the wind farm to the grid (TransGrid lines, including easement width and height), on site control room and equipment storage, temporary concrete batching plant(s), construction compounds, access roads/road upgrades (including access tracks) and obstacle lighting;</li> <li>→ a timeline identifying the proposed construction and operation of the project components, their envisaged lifespan and arrangements for decommissioning and staging;</li> <li>→ supporting maps/plans clearly identifying existing environmental features (e.g. watercourses, vegetation), infrastructure and landuse (including nearby residences and approved residential developments or subdivisions) and the location/ siting of the project (including associated infrastructure) in the context of this existing environment; and</li> <li>→ resourcing requirements (including, but not limited to, water supply and gravel).</li> </ul> </li> <li>• consideration of any <b>relevant statutory provisions</b> including the consistency of the project with the objects of the <i>Environmental Planning and Assessment Act 1979</i> and any relevant development control plans;</li> <li>• an <b>assessment of the key issues</b> outlined below, during construction, operation and decommissioning (as relevant). The Environmental Assessment must assess the worst case as well as representative impact for all key issues considering cumulative impacts, as applicable;</li> <li>• a <b>draft Statement of Commitments</b> detailing measures for environmental mitigation, management and monitoring for the project;</li> </ul>

	<ul style="list-style-type: none"> <li>• a <b>conclusion justifying the project</b> taking into consideration the environmental, social and economic impacts of the project; the suitability of the site; and the public interest; and</li> <li>• <b>certification by the author</b> of the EA that the information contained in the Assessment is neither false nor misleading.</li> </ul> <p>Given the length of the grid connection transmission line, the EA should present, with respect to each relevant transmission line impact, a considered screening of potential impacts along the length of the line, to identify areas of potentially significant impact for further, more detailed assessment. In addition to detailed assessment of areas of potentially significant impact, other areas along the length of the line should be assessed in a more general manner, with a particular focus on the development of frameworks for the mitigation, management and monitoring of more minor and generic environmental issues.</p>
<b>Key Assessment Requirements</b>	<p>The EA must include assessment of the following key issues for both the wind farm and transmission line:</p> <ul style="list-style-type: none"> <li>• <b>Strategic Justification</b> - the EA must: <ul style="list-style-type: none"> <li>→ include a strategic assessment of the need, scale, scope and location for the project in relation to predicted electricity demand, predicted transmission constraints and the strategic direction of the region and the State in relation to electricity supply, demand and electricity generation technologies, and its role within the Commonwealth's Renewable Energy Target Scheme;</li> <li>→ include a clear demonstration of quantified and substantiated greenhouse gas benefits, taking into consideration sources of electricity that could realistically be replaced and the extent of their replacement;</li> <li>→ include an analysis of the suitability of the project with respect to potential land use conflicts with existing and future surrounding land uses (including rural residential development, land of significant scenic or visual value, land of high agricultural value, mineral reserves, forestry and conservation areas), taking into account local and strategic landuse objectives; and</li> <li>→ describe the alternatives considered (location and/or design) for all project components, and provide justification for the preferred project demonstrating its benefits including community benefits (for example community enhancement programmes) on a local and strategic scale and how it achieves stated objectives.</li> </ul> </li> <li>• <b>Visual Impacts</b> - the EA must: <ul style="list-style-type: none"> <li>→ provide a comprehensive assessment of the landscape character and values and any scenic or significant vistas of the area potentially affected by the project, including both the wind farm and the transmission line. This should describe community and stakeholder values of the local and regional visual amenity and quality, and perceptions of the project based on surveys and consultation;</li> <li>→ assess the impact of shadow "flicker", blade "glint" and night lighting from the wind farm;</li> <li>→ identify the zone of visual influence of the wind farm (no less than 10 kilometres) and assess the visual impact of all project components on this landscape;</li> <li>→ include an assessment of the visual impacts associated with the transmission line, including impacts on local and regional views. Alternative pole designs should be presented and assessed and the potential for undergrounding in sensitive locations should also be assessed;</li> <li>→ include photomontages of the project taken from potentially affected residences (including approved but not yet developed dwellings or subdivisions with residential rights), settlements and significant public view points, and provide a clear description of proposed visual amenity mitigation and management measures for both the wind farm and the transmission line;</li> <li>→ provide an assessment of the feasibility, effectiveness and reliability of proposed mitigation measures and any residual impacts after these measures</li> </ul> </li> </ul>

have been implemented.

- **Noise Impacts** - the EA must:

- include a comprehensive noise assessment of all phases and components of the project including, but not limited to turbine operation, the operation of the electrical substation, corona and / or aeolian noise from the transmission line, construction noise (focusing on high noise-generating activities and any works proposed outside of standard construction hours), traffic noise during construction and operation, and vibration generating activities (including blasting) during construction and/ or operation. The assessment must identify noise/ vibration sensitive locations (including approved but not yet developed dwellings), baseline conditions based on monitoring results, the levels and character of noise (e.g. tonality, impulsiveness etc) generated by noise sources, noise/ vibration criteria, modelling assumptions and worst case and representative noise/ vibration impacts;
- in relation to wind turbine operation, determine the noise impacts under operating meteorological conditions (i.e. wind speeds from cut in to rated power), including impacts under meteorological conditions that exacerbate impacts (including varying atmospheric stability classes and the van den Berg effect for wind turbines). The probability of such occurrences must be quantified;
- include monitoring to ensure that there is adequate wind speed/profile data and ambient background noise data that is representative for all sensitive receptors;
- provide justification for the nominated average background noise level used in the assessment process, considering any significant difference between daytime and night time background noise levels;
- identify any risks with respect to low frequency or infra-noise;
- if any noise agreements with residents are proposed for areas where noise criteria cannot be met, provide sufficient information to enable a clear understanding of what has been agreed and what criteria have been used to frame any such agreements;
- clearly outline the noise mitigation, monitoring and management measures that would be applied to the project. This must include an assessment of the feasibility, effectiveness and reliability of proposed measures and any residual impacts after these measures have been incorporated; and
- include a contingency strategy that provides for additional noise attenuation should higher noise levels than those predicted result following commissioning and/or noise agreements with landowners not eventuate.

The assessment must be undertaken consistent with the following guidelines:

- Wind Turbines - the South Australian Environment Protection Authority's *Wind Farms - Environmental Noise Guidelines* (2003);
- Substation – *NSW Industrial Noise Policy* (EPA, 2000);
- Site Establishment and Construction – *Interim Construction Noise Guidelines* (DECC, 2009);
- Traffic Noise – *Environmental Criteria for Road Traffic Noise* (NSW EPA, 1999); and
- Vibration – *Assessing Vibration: A Technical Guideline* (DECC, 2006).

- **Flora and Fauna** - the EA must:

- include an assessment of all project components on flora and fauna (both terrestrial and aquatic, as relevant) and their habitat consistent with the *Draft Guidelines for Threatened Species Assessment* (DEC, 2005) and taking into account the *Murrumbidgee Catchment Action Plan* (Murrumbidgee CMA), including details on the existing site conditions and likelihood of disturbance (including quantifying the worst case extent of impact on the basis of vegetation type and total native vegetation disturbed);
- The EA must specifically consider impacts to threatened species and communities listed under both State and Commonwealth legislation that have been recorded on the site and surrounding land, impacts to riparian and/ or

	<p>instream habitat in the case of disturbance of waterways, and to biodiversity corridors. In addition, impact of the project on birds and bats from blade strikes, low air pressure zones at the blade tips (barotrauma), and alteration to movement patterns resulting from the turbines must be assessed, including demonstration of how the project has been sited to avoid and/ or minimise such impacts. In particular, the EA must address the impact on Eastern Bentwing Bats (including those foraging from the Wee Jasper maternity cave and utilising the Black Andrew Nature Reserve), the Eastern False Pipistrelle Bat, Box-Gum Woodland Endangered Ecological Community and the Yass Daisy. In the case of the Eastern Bentwing Bat, the EA must address the research programme identified by DECCW;</p> <ul style="list-style-type: none"> <li>→ details of how flora and fauna impacts would be managed during construction and operation including adaptive management and maintenance protocols (including the mitigation and/or management of weeds); and</li> <li>→ measures to avoid, mitigate or offset impacts consistent with "improve or maintain" principles. Sufficient details must be provided to demonstrate the availability of viable and achievable options to offset the impacts of the project.</li> </ul> <ul style="list-style-type: none"> <li>• <b>Indigenous Heritage</b> - the EA must include an assessment of the potential impact of the project components on indigenous heritage values (archaeological and cultural). The EA must demonstrate effective consultation with indigenous stakeholders during the assessment and in developing mitigation options (including the final recommended measures) consistent with <i>Guidelines for Aboriginal Cultural Impact Assessment and Community Consultation</i> (DEC, July 2005).</li> <li>• <b>Traffic and Transport</b> – the EA must assess the construction and operational traffic impacts of the project including: <ul style="list-style-type: none"> <li>→ details of the nature of traffic generated, transport routes, traffic volumes and potential impacts on local and regional roads (including impacts on the structural integrity of the road network), bridges and intersections, including any proposed road upgrades and repairs;</li> <li>→ details of measures to mitigate and/or manage the potential impacts, including measures to control soil erosion and dust generated by traffic volumes;</li> <li>→ details of site access roads including how these would connect to the existing road network and any operational maintenance or handover requirements.</li> </ul> </li> <li>• <b>Hazard/Risks</b>– the EA must include an assessment of the potential impacts on aviation safety including the need for aviation hazard lighting considering nearby aerodromes and aircraft landing areas, defined air traffic routes, aircraft operating heights, radar interference, communication systems, and navigation aids. Aerodromes within 30km of the turbines should be identified and impacts on obstacle limitation surfaces addressed. In addition, the EA must assess the impact of the turbines on the safe and efficient aerial application of agricultural fertilisers and pesticides in the vicinity of the turbines and transmission line. Possible effects on telecommunications systems must be identified. Potential hazards and risks associated with electric and magnetic fields (EMFs) (with reference to Australian Radiation Protection and Nuclear Safety Agency standards) and bushfires must be assessed. The EA should demonstrate the application of the Principles of Prudent Avoidance in relation to EMFs. The EA must also detail measures to contain any hazardous substances to prevent the contamination of pasture and dams.</li> <li>• <b>Water Supply, Water Quality and Waterways</b> – The EA must determine whether an adequate and secure water supply is available for the life of the project including the statutory (licensing)/water sharing plan context of the water supply sources, and assess potential environmental impacts associated with the identified sources, including impacts on groundwater. Where project elements would cross significant waterways, the EA must identify likely impacts to the waterways and measures to minimise impacts, including protection of riparian zones. Details of the design of waterway crossings where such crossings are to be located in third order or higher streams are to be provided. The EA must also address soil erosion</li> </ul>
--	--



	<p>issues and the potential for clearing to create a salinity risk.</p> <ul style="list-style-type: none"> <li>• <b>General Environmental Risk Analysis</b> – notwithstanding the above key assessment requirements, the EA must include an environmental risk analysis to identify potential environmental impacts associated with the project, proposed mitigation measures and potentially significant residual environmental impacts after the application of proposed mitigation measures. Where additional key environmental impacts are identified through this environmental risk analysis, an appropriately detailed impact assessment of the additional key environmental impact(s) must be included in the EA.</li> </ul>
<b>Consultation Requirements</b>	<p>The Proponent must undertake a consultation programme as part of the environmental assessment process, including consultation with, but not necessarily limited to, the following parties:</p> <ul style="list-style-type: none"> <li>• Gundagai Shire Council;</li> <li>• Department of Environment, Climate Change and Water;</li> <li>• NSW Office of Water;</li> <li>• Department of Industry and Investment;</li> <li>• NSW Roads and Traffic Authority;</li> <li>• NSW Rural Fire Service;</li> <li>• Land and Property Management Authority;</li> <li>• Murrumbidgee CMA;</li> <li>• TransGrid</li> <li>• Commonwealth Department of Defence;</li> <li>• Civil Aviation Safety Authority;</li> <li>• Airservices Australia;</li> <li>• Aerial Agricultural Society of Australia;</li> <li>• relevant minerals stakeholders (including exploration and mining title holders); and</li> <li>• the local community and landowners.</li> </ul> <p>The consultation process shall include measures for disseminating information to increase awareness of the project as well as methods for actively engaging stakeholders on issues that would be of interest/concern to them. The EA must:</p> <ul style="list-style-type: none"> <li>→ demonstrate effective consultation with stakeholders, and that the level of consultation with each stakeholder is commensurate with their degree of interest/concern or likely impact;</li> <li>→ clearly describe the consultation process undertaken for each stakeholder/group including details of the dates of consultation and copies of any information disseminated as part of the consultation process (subject to confidentiality); and</li> <li>→ describe the issues raised during consultation and how and where these have been addressed in the EA.</li> </ul>

## Relevant Guidelines - For Reference

---

### General

Wind Energy Facilities draft Environmental Impact Assessment Guidelines (Planning NSW, June 2002)

Draft EIS Guideline "Network Electricity Systems and Related Facilities" (Planning NSW, February, 2002)

Best Practice Guidelines for Implementation of Wind Energy Projects in Australia (Auswind, 2006)

---

### Visual

Wind Farms and Landscape Values: National Assessment Framework (Australian Wind Energy Association and Australian Council of National Trust, June 2007).

---

### Ecology

Cumulative Risk for Threatened and Migratory Species (Commonwealth Department of Environment and Heritage, March 2006).

Wind Farms and Birds: Interim Standards for Risk Assessment, (Auswind, July 2005).

Assessing the Impacts on Birds – Protocols and Data Set Standards (Australian Wind Energy Association).

Threatened Biodiversity Survey and Assessment – Guidelines for Developments and Activities (Working Document) (DEC, 2004).

---

### Aviation Hazard

Advisory Circular 139-18(0) Obstacle Marking and Lighting of Wind Farms (Civil Aviation Safety Authority, July 2007). Note: this advisory is currently withdrawn however a replacement has to date not been issued.

Windfarm Policy (Aerial Agricultural Association of Australia, December 2009)

Powerlines Policy (Aerial Agricultural Association of Australia, December 2009)

---

### Water Quality

National Water Quality Management Strategy: Australian and New Zealand Guidelines for Fresh and Marine Water Quality (ANZECC 2000).

The NSW State Groundwater Quality Protection Policy (DLWC, 1998).

The NSW State Groundwater Dependent Ecosystems Policy (DLWC, 2002).

Department of Water and Energy's Guidelines for Controlled Activities (February 2008):

- Watercourse Crossings;
- Instream Works;
- Laying Pipes and Cables in Watercourses;
- Outlet Structures; and
- Riparian Corridors.

Managing Urban Stormwater: Soils and Construction, Volume 1, 4<sup>th</sup> edition (Landcom, 2004).

Managing Urban Stormwater: Soils and Construction, Volume 2C Unsealed roads (DECC).

---