

BUILDING CODE OF AUSTRALIA 2011 REPORT

Tom O'Neill Centre BCA Report
Graythwaite, 20 Edward Street, North Sydney
16 September 2011
Project No. 251068



Project Contacts

Client:	SHORE School
Project Manager:	Tanner Architects
Building Surveying:	Charles Slack-Smith – Davis Langdon

CONTENTS

1. BACKGROUND.....	3
2. INTRODUCTION.....	4
3. BUILDING DESCRIPTION.....	5
4. BCA UPGRADE ITEMS PROPOSED.....	6
5. BCA NON-COMPLIANCES – NOT PROPOSED TO BE UPGRADED.....	7
6. ESSENTIAL FIRE & OTHER SAFETY MEASURES.....	8
7. RECOMMENDATIONS.....	9

Appendix 1: Detailed BCA Assessment of Buildings

Appendix 2: Fire Resistance Provisions

DL Quality System

Job Number/Ref:	251068	Revision Number:	F	Issue Date:	16.9.2011
Checked By:	Brett Claburn	Author:	Charles Slack-Smith		
Distribution:	All				

Revision History

Rev No.	Date	Revision Details	Author	QA Check
A	7.9.2010	BCA Assessment	CSS	BC
B	22.9.2010	Amendment to BCA Assessment	CSS	BC
C	12.11.2010	Amended based on client comments	CSS	BC
D	17.6.2011	Amendment for Part 3A comments	CSS	BC
E	23.6.2011	Amendment for Part 3A comments	CSS	BC
F	16.9.2011	Amended to reflect Sanitary facilities	CSS	BC

1. BACKGROUND

The project involves the refurbishment of an existing building for use as a music classroom building.

This report outlines the current areas of non-compliance with the BCA, and then outlines the anticipated requirements required to be upgraded to ensure an appropriate level of fire and life safety for the building as required by Clause 94 of the EP & A Regulations for assessment by the consent authority.

2. INTRODUCTION

Property Description

The report is for the assessment of the former Tom O'Neill Centre at Graythwaite, North Sydney, in order to assess compliance with the Building Code of Australia 2010 ("BCA"). A summary of all relevant clauses of the BCA is attached under Appendix 1.

The report is prepared based on a visual inspection of the premises and review of the developed documentation.

Reporting Team

The information contained within this report was prepared by Charles Slack-Smith Accredited Certifier Grade A1 (BPB 0378) from Davis Langdon.

Current Legislation

The applicable legislation governing the design of buildings is the Environmental Planning and Assessment Act 1979.

This report is split into sections, those existing non-compliances with the building to be fire engineered, those non-compliances that have been proposed to be upgraded or addressed by the design team, and those items of non-compliance listed for assessment by the consent authority as to whether an upgrade will be required under the provisions on Clause 94 of the Environmental Planning and Assessment Regulation 2000 as required to be assessed as listed below.

Clause 94 - Consent authority may require buildings to be upgraded (EP & A Regulation 2000)

- (1) This clause applies to a development application for development involving the rebuilding, alteration, enlargement or extension of an existing building where:
 - (a) the proposed building work, together with any other building work completed or authorised within the previous 3 years, represents more than half the total volume of the building, as it was before any such work was commenced, measured over its roof and external walls, **or**
 - (b) the measures contained in the building are inadequate:
 - i. to protect persons using the building, and to facilitate their egress from the building, in the event of fire, or
 - ii. to restrict the spread of fire from the building to other buildings nearby.
- (2) In determining a development application to which this clause applies, a consent authority is to take into consideration whether it would be appropriate to require the existing building to be brought into total or partial conformity with the Building Code of Australia.
- (3) **The matters prescribed by this clause are prescribed for the purposes of section 79C (1) (a) (iv) of the Act.**

As such those matters listed in the upgrading section are the only ones proposed to be upgraded as part of these works and unless a specific DA condition requiring an upgrade for the other items is provided then this is all the upgrading works that the Applicant is anticipating to be undertaken as part of these works.

The provisions of this Act and Regs, in particular Clause 98, require that all new building works are to be designed in accordance with the technical provisions of the State's building laws and in particular, the Building Code of Australia 2010 which will be achieved for any new works.

3. BUILDING DESCRIPTION

The Project

The project involves the refurbishment of the Tom O'Neill Building for use as a class room / teaching space, the existing buildings are significant heritage buildings in a state of disrepair.

Building Description

Building Use:	Classroom / Teaching space
Class of Occupancy:	Class 9b
Type of Construction:	Type C
Rise in Storeys:	One
Levels Contained:	One
Floor Area:	Approx 529m2
Effective Height:	Less than 12m

Note: As the Construction Certificate application is to be lodged after 1st May 2011 then the provisions of BCA 2011 will apply to the project which may have design ramifications to the design of the project particularly in regards to disabled access provisions, this is to be assessed by the teams Disabled Access consultant and advice given, this report is not assessing the disabled access changes of BCA 2011, all other areas are assessed to BCA 2011.

Documentation Assessed

This report is based on the following Architectural Plans issued by Tanner Architects for the building:

Description	Drawing No.	Revision	Date
Tom O'Neill Centre – Proposed Plans, Sections & Elevations	AR.DA.4001	P1	7/8/2010

4. BCA UPGRADE ITEMS PROPOSED

1. BCA Clause D2.21 & E4.2 - Egress Doors – the two existing doors opening to outside are required exit doors and as such are required to be provided with:
 - Exit signage over these door – illuminated running man exit signage to AS 2293.1-2005
 - Door Latching to be a single, lever action door hardware openable from the inside without a key (no snib locks or multiple locking devices)
 - As they swing in the direction of travel these are the only two exits that are required from the building

See Note 1 below
6. BCA Clause E1.3 Fire Hydrant System – the external fire hydrant system is to be assessed by a Hydraulic Consultant to confirm compliance to current requirements including coverage to the building, or is to be upgraded to achieve current compliance for this building; coverage to the building is to be assessed to confirm that compliant coverage is provided to the building, and if any works are required to the hydrant system are to be undertaken to ensure compliance is achieved for the building.
7. BCA Clause E1.4 Fire Hose Reel – the Fire hose reel system for the building is to be provided to achieve compliance; a hydraulic engineer is to check and confirm compliance for the system, however the FHR will need to be located within 4m of one of the exits from the building to achieve compliance. – *See Note 1 below*
8. BCA Clause E2.2 – Smoke Hazard management system – the building is to be provided with a smoke detection system to enable shutdown of any mechanical or air conditioning systems in the building as required by Clause E2.2a and AS 1668 as required. – *See Note 1 below*
9. BCA Clause E2.2 – Smoke Hazard management system – the building's mechanical ventilation system is to be provided with a fire trip link to shut down all air conditioning / mechanical ventilation systems on fire trip from the detection system. (except for all miscellaneous systems as defined in AS 1668) – *See Note 1 below*
10. BCA Clause F2.3 Toilet Numbers – it is proposed that the following toilet numbers be provided to the building to ensure compliance for the proposed population of the building as follows:

Class 9b Staff (caters for staff of 10)

 - 1 Unisex Disabled facility is required if toilets are provided – unless the disabled access consultant is able to issue an Alternative solution for non-provision of a disabled toilet in which case 1 unisex toilet is all that is required to cater for up to 10 staff members.
 - Class 9b Classroom students facilities – The students are advised as utilising the facilities of the main school campus as such toilet facilities are sufficient based upon this provision, details confirming will be required at the Construction Certificate stage of the development should consent be granted.

Note 1: some or all of these fire related upgrade items may be subject to a fire safety engineers alternative solution, this assessment will be undertaken prior to issue of the Construction Certificate and will be assessed against the performance provisions of the BCA as opposed to the strict BCA Deemed to Satisfy provisions listed above.

5. BCA NON-COMPLIANCES – NOT PROPOSED TO BE UPGRADED

Items of Current Non-compliance not proposed to be upgraded by the applicant for consent authority's assessment

The non-compliant items that are not being proposed to be upgraded / addressed by the proposed works are summarized below. The consent authority is to assess if these items are to be upgraded and a specific condition identifying which items are to be upgraded is requested to be provided with the Development Consent if these are not agreed to:

1. BCA Clause D3 Disabled Access – due to the age of the building and heritage nature it is not proposed for the building to be fully upgraded to achieve compliance to all of the requirements of this part of the BCA and AS 1428.1, an Access consultant will need to be engaged to provide advice on the level of **Disabled Access** that is able to be provided to the building but due to the heritage nature of the building this will not achieve BCA compliance for the building.
2. BCA Part J – Existing parts of the building not being altered by these works are not proposed to be upgraded to comply with this part of the BCA, an example being the external walls of the building which are not known to achieve compliance and an upgrade for **Section J Energy Efficiency** is not proposed. All new works installed will achieve compliance where possible with Section J compliance in these buildings.

6. ESSENTIAL FIRE & OTHER SAFETY MEASURES

Below is a list of essential fire safety services that are installed and those that will be required to be installed within the building.

Fire Safety Measure	Standard	BCA Clause(s)	Existing Fire Safety Measures	Proposed Fire Safety Measures
Automatic fail safe devices *	-	D2.21	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Smoke detection & alarm systems*	AS 1668.1-1998	E2.2	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Emergency lighting	AS 2293.1 – 2005	E4.2, E4.4	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Exit signs	AS 2293.1 – 2005	E4.5, NSW E4.6 & E4.8	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Fire hose reel systems*	AS 2441 – 2005	E1.4	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Fire hydrant systems (external)	AS 2419.1 – 2005	E1.3	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Mechanical air handling systems & fire trip shutdown *	AS 1668.2 – 1991, and AS 1668.1-1998	Part F4 & E2.2	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Portable fire extinguishers & fire blankets	AS 2444 – 2001	E1.6	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Other Measures:				
Paths of Travel	-	D1.6	<input type="checkbox"/>	<input checked="" type="checkbox"/>

* See Note 1 on page 6 regarding potential fire safety engineering for some of these fire safety measures

7. RECOMMENDATIONS

Those measures listed in Section 4 of this report, under the Upgrade Section are to be included in the design of the building, to ensure an appropriate level of fire and life safety is provided for the building.

Appendix 1

BCA Provisions

The following is a clause-by-clause assessment of the architectural drawings against the deemed-to-satisfy provisions of the BCA 2010.

Notes:

- ✓ The building complies with this clause or new works be able to achieve compliance to this clause.
- CA** The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.
- ?** Further documentation required.
- CR** Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
- N/A** This clause is not applicable to this project.
- AS** Alternative Solution using Performance Requirements proposed to justify this measure.
- Noted** This clause is for information.

Section A: General Provisions

Icon	Clause	Reference	Comment
	A3	<i>Classification of buildings and structures</i>	
✓		The classification of a building is determined by the purpose for which it is designed, constructed or adapted.	Class 9b school classroom
	A3.3	<i>Multiple classification</i>	
Noted		Each part must be classified separately: (a) Classified to the major use if not more than 10% of the floor area of the storey. (b) Plant rooms are classified as the same part.	
	A4	<i>PART A4 – UNITED BUILDINGS</i>	
	A4.1	<i>When buildings are united</i>	
N/A		Two or more buildings adjoining each other form one united building if they are connected through openings in the walls dividing them and both buildings comply with the requirements of the BCA as though they are a single building.	

Section B: Structural Provisions

Icon	Clause	Reference	Comment
	B1.1	Resistance to actions & Loads	
	B1.2	Determination of individual actions	
CR		<p>The building or structure must resist loads determined in accordance with the following:</p> <ul style="list-style-type: none"> (a) Dead and live load combinations: AS 1170.1 (b) Wind loads AS 1170.2 (c) Snow loads AS 1170.3 (d) Earthquake loads AS 1170.4 	Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
	B1.3	Materials and forms of construction	
CR		<p>The building or structure must resist loads determined in accordance with the following:</p> <ul style="list-style-type: none"> (a) Dead and live load combinations: AS 1170.1 (b) Wind loads AS 1170.2 (c) Snow loads AS 1170.3 (d) Earthquake loads AS 1170.4 	Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
	B1.4	Materials and forms of construction	
CR / CA		<p>New materials and forms of construction are to be designed to the following Australian Standards as applicable:</p> <ul style="list-style-type: none"> (a) AS 3700 (b) AS 3600 (c) AS 4100 (d) AS 1288 or AS 2047 (e) AS 1562.1 (f) AS 1720.1 (g) AS 3660.1 	Note – all new installations / works will comply, all existing glazing and works etc are not proposed to be upgraded due to the heritage nature of the building

Section C: Fire Provisions

Part C1 – Fire Resistance and Stability

Icon	Clause	Reference	Comment
	C1.1	Type of construction	
✓		Type of Construction required is determined by the Table C1.1	Type C
	C.1.2	Calculation of rise in storeys	
✓		The rise in storeys is the greatest number of storeys at any part of the external walls of the building above the finished ground next to that part.	RIS of 1
	C1.3	Building of multiple classification	
Noted		The Type of construction required is determined on the basis that the classification of the top storey applies to all storeys.	
	C1.4	Mixed types of construction	
Noted		Building may be of mixed Types of Construction where it is separated in accordance with C2.7	
	C1.5	Two storey Class 2 or 9c buildings	
N/A		Class 2 or 3 of two storeys may be Type C construction if each SOU has: <ul style="list-style-type: none"> 1. Access to at least 2 exits; or 2. Its own direct access to a road or open space. 	
	C1.6	Class 4 parts of a building	
Noted		Class 4 part of a building requires same FRL as that required by a Class 2 in similar circumstances.	
	C1.7	Open spectator stands and indoor sports stadium	
N/A		May be of Type C construction if it contains only 1 tier and is of non-combustible material.	
	C1.8	Lightweight construction	
N/A		Lightweight construction may be used if it is in compliance with Specification C1.8.	

Icon	Clause	Reference	Comment
	C1.10	Fire hazard properties	
CR / CA		<p>Materials and assemblies used in the building must comply with the requirements of Specification C1.10. In the case of a sarking material the Flammability Index shall not be more than 5.</p> <p>Tom O'Neill</p> <p>Floor materials – Critical Radiant Flux of not less than 2.2</p> <p>Wall and Ceiling materials – Either Group 1 or 2 material (note: timber finishes may not achieve a group 1 or 2 requirement)</p>	<p>New installations will need to achieve compliance</p> <p>Existing linings are not to be upgraded nor where new linings are installed to patch/repair existing linings as these are related to the heritage finishes of the buildings and are not proposed to be upgraded</p>
	C1.11	Performance of external wall in fire	
N/A		In buildings of up to two storeys, any concrete external walls that could collapse as complete panels to comply with specification C1.11.	
	C1.12	Non-combustible materials	
Noted		<p>The following materials may be used where non-combustible materials are required:</p> <ol style="list-style-type: none"> 1. Plasterboard. 2. Perforated gypsum. 3. Fibrous-plaster sheeting to AS 2185. 4. Fibre-reinforced cement sheeting. 5. Pre-finished metal sheeting. 6. Bonded laminated materials. 	

Part C2 – Compartmentation and Separation

Icon	Clause	Reference	Comment
	C2.2	General floor area limitations	
✓		<p>Table C2.2 limits the size of fire compartments to:-</p> <ul style="list-style-type: none"> • Class 5 or 9b Type C, 3,000m² & 18,000m³ <p>See Section 3,4 or 5 of Specification C1.1 for specific fire rating requirements (a brief table of FRL's is included in the appendix for information – detailed requirements in abovementioned section of the BCA)</p>	Buildings are less than the max fire compartment sizes for these classes

Icon	Clause	Reference	Comment
	C2.3	Large isolated buildings	
N/A		<p>A fire compartment may exceed that specified in Table C2.2. Buildings under of exceeding 18,000m² in floor area to be provided with specific requirements</p> <p>Generally a sprinkler system complying with Specification E1.5 provided with a perimeter vehicular access complying with C2.4 (b) – additional measures may include a smoke exhaust system in accordance with Specification E2.2b or smoke-and-heat vents in accordance with Specification E2.2c.</p>	
	C2.4	Requirements for open spaces and vehicular access	
N/A		<p>Requirements for open spaces and vehicular access capable of supporting emergency vehicles, 6m wide not more than 18m from the building.</p> <p>Part a – 18m wide open space without any buildings or obstructions whatsoever, and must also comply with part b of this section.</p>	
	C2.5	Class 9a & 9c buildings	
N/A		Class 9a & 9c Fire Compartmentation and separation requirements	
	C2.6	Vertical separation of openings in external walls	
N/A		<p>Only applicable to a building of Type A Construction, that is not sprinkler-protected. – no requirement is applicable for spandrel separation of a Sprinkler protected building.</p> <p>If not Sprinkler protected either 900mm vertical spandrel required, or 1m horizontal projecting spandrel – specific details in this clause of the BCA</p>	
	C2.7	Separation by fire walls	
N/A		A part of a building separated by firewall construction may be considered a separate building for the purposes of Parts C, D and E. (Must continue directly from on ground floor slab straight up through the building to top)	
	C2.8	Separation of classifications in the same storey	
N/A		Firewalls are needed to separate different classifications, or the building must be built to the higher fire resistance level.	
	C2.9	Separation of classifications in different storeys	
N/A		The separating floors must have an FRL not less than that required for the lower storey use.	
	C2.10	Separation of lift shafts	
N/A		The lift is to be enclosed in a fire-isolated shaft if it connects more than two storeys or three storeys if provided with a sprinkler system.	

Icon	Clause	Reference	Comment
	C2.11	Stairs and lift in one shaft	
N/A		Not to be within the same shaft if either is required to be fire isolated.	
	C2.12	Separation of equipment	
Noted		Equipment comprising lift motors and control plant, emergency generators or central smoke control plant; boilers or batteries are required to be separated from the remainder of the building by construction achieving a FRL of 120/120/120.	
	C2.13	Electricity supply system	
Noted		A substation located within a building or main switchboard, which sustains emergency equipment, must be separated from the remainder of the building by construction achieving a FRL of not less than 120/120/120.	
	C2.14	Public corridors in Class 2 & 3 buildings	
N/A		In a Class 3 building, a public corridor, if more than 40m in length, must be divided at intervals of not more than 40m with smoke-proof walls complying with Cl. 2 of Spec C2.5.	

Part C3 – Protection of Openings

Icon	Clause	Reference	Comment
	C3.2	Protection of opening in external walls	
✓		<p>Openings in the external walls are to be protected in accordance with C3.4 if:-</p> <ul style="list-style-type: none"> <input type="checkbox"/> less than 3m to side or rear boundary <input type="checkbox"/> less than 6m from the far boundary of a road if not located at or near ground level <input type="checkbox"/> less than 6m from another building on the same allotment. 	
	C3.3	Separation of external walls and associated openings in different fire compartment	
✓		External walls of a different fire compartment to be separated by a fire wall of not less than FRL 60/60/60 or any openings must be protected in accordance with Clause C3.4 if within the distance set out in Table C3.3.	
	C3.4	Acceptable methods of protection	
Noted		Where exposed to be protected by external or internal drenchers (side of protection specified by relevant clause that calls up protection), fire doors, windows or shutters.	
	C3.5	Doorways in fire walls	
N/A		<p>Doorways in a fire wall which are not part of a horizontal exit, must not exceed ½ the length of the fire wall, and:</p> <ol style="list-style-type: none"> 1. have the FRL required for the fire wall, and 2. be self-closing or automatic-closing. 	

Icon	Clause	Reference	Comment
	C3.6	Sliding fire doors	
N/A		If utilised must fail safe in the closed position, be suitably signposted with an audible alarm, signage and directional arrow to indicate direction to slide door to open when in the closed position.	
	C3.7	Doorways in horizontal exits	
N/A		To be suitably protected by fire doors with FRL of not less than that required for the fire wall, and be self-closing or automatic-closing. And must swing in the direction of travel (this may be both ways if so either two doors or a multi directional swing fire door is required)	
	C3.8	Openings in fire isolated exits	
N/A		To be automatic magnamatic or self closing -/60/30 fire doors.	
	C3.9	Service penetrations in fire isolated exits	
N/A		Fire exits must not be penetrated by services other than electrical wiring associated with lighting, stair pressurisation or the intercommunication system & hydrant system.	
	C3.10	Openings in fire rated lift shafts	
N/A		<input type="checkbox"/> Doors to be - /60/ - fire doors to AS1735.11. <input type="checkbox"/> Lift indicator panels to be backed by - /60/60 construction if exceeding 35,000mm ² in area.	
	C3.11	Bounding Construction; Class 2, 3 & 4 buildings	
N/A		Doorway to each SOU to be protected; <ul style="list-style-type: none"> -/60/30 in Type A construction Self-closing, tight fitting, solid core door, not less than 35mm thick in Type B or C construction 	
	C3.12	Openings in floors for services	
N/A		To be enclosed in a fire rated shaft with a FRL in accordance with Specification C1.1 or protected by Clause C3.15 of BCA	
	C3.13	Openings in shafts	
N/A		Openings in ventilating, pipe, garbage or other service shaft to be protected by:- -/60/30 fire doors / hoppers / access panel.	
	C3.15	Openings for service installations	
N/A		Electrical, plumbing mechanical ventilation shafts etc not to impair the FRL of rated members.	

Specification C1.1 – Fire Resisting Construction

Icon	Clause	Reference	Comment
	5	Type C Fire Resisting Construction – Tom O'Neill Centre	
CA	5.1	Table 5. External Loadbearing Walls within 1.5m of the boundary (or other fire source feature) require a FRL of 90/90/90. External Loadbearing Walls between 1.5m and 3m of the boundary (or other fire source feature) require a FRL of 60/60/60. Fire Walls require an FRL of 90/90/90.	

Specification C1.10 – Early Fire Hazard Indices

Icon	Clause	Reference	Comment
	4	Class 2, 3 and 9 Buildings	
N/A		Further specific provisions relate to POPE for NSW for closed back seats, screens, curtains, blinds or similar decor.	See C1.10/a in report for floor and wall lining requirements for new wall linings

Specification C1.10a – Fire Hazard Properties – Floors, Walls and Ceilings

Icon	Clause	Reference	Comment
	4	Lift cars	
N/A		In a lift car, the floor materials and floor coverings must have a Critical radiant heat flux not less than 2.2 and wall and ceiling linings must be a Group 1 or Group 2 material in accordance with Clause 3(b).	

Section D: Access and Egress

Part D1 – Provision for Escape

Icon	Clause	Reference	Comment
	D1.2	Number of exits required	
✓		<p>The number of exits is to be designed to satisfy performance standard DP4 of the BCA.</p> <p>A minimum of one exit is required from all buildings, and</p> <p>Two (2) exits for each storey are required for buildings over 25m, class 9b areas that exceed 50 persons.</p>	
	D1.3	When fire isolated exits are required	
N/A		<p>Every stair in a building must be fire isolated unless it does not connect or pass through more than 3 consecutive floors in a sprinkler protected building or 2 storeys in a non-sprinkler protected building.</p> <p>Class 9a & 9c buildings require stairs to be fire isolated.</p> <p>Those stairs not requiring fire isolating must discharge at a level of road or open space</p>	
	D1.4	Exit travel distances	
✓		<p>No point on the floor must be more than 20m to an exit or a point in which travel in different directions to 2 exits is available, in which case, the maximum distance to 1 exit cannot exceed 40m.</p> <p>Class 5 or 6 buildings with only one exit, and opening to road or street may have greater distance of up to 30m to that single exit.</p>	
	D1.5	Distance between alternative exits	
✓		<p>To be no less than 9m or more than 45m in a Class 2, 3, and 9a, or 60m in all other classes, uniformly distributed with access to 2 exits if required and not converge so they become less than 6m apart.</p>	
	D1.6	Dimensions of exits and paths of travel	
CA		<p>(a) height – minimum 2m: doorways 1980mm</p> <p>(b) width 1m minimum</p> <p>(c);(d) Width change based upon populations – generally for populations up to 100 persons require 1m of egress, up to 200 2m and then varies according to use over 200 person per floor / storey.</p> <p>(f) door width minimum 800mm clear opening</p> <p>(g) not to diminish in direction of travel.</p> <p>Note: see also re number of exits for certain uses Clause D1.2 as may require additional exits no matter the population of the storey.</p>	<p>New works are to achieve compliance</p> <p>Existing works are not proposed to be upgraded</p>
	D1.7	Travel by fire isolated stairs	
N/A		<p>Must provide independent egress and discharge to road or open space or complying covered area.</p>	

Icon	Clause	Reference	Comment
	D1.8	External stairs or ramps in lieu of fire isolated exits	
N/A		External stairs or ramps may be used in lieu of a fire-isolated stair or ramp to a building under 25m in effective height.	
	D1.9	Travel by non fire isolated stairs	
N/A		Travel by Non-Fire Isolated Stairs:- (c) The distance from any point on the floor to a point of egress not to exceed 80m. (e) The stairway not to discharge at a point more than: (i) 20m to an exit (ii) 40m to one of 2 exits.	
	D1.10	Discharge from exits	
✓		An exit must not be blocked nor be capable of being blocked at its point of discharge. Ramp to a grade of 1:8 is required to connect with open space.	
	D1.11	Horizontal exits	
N/A		May be counted as required exits if the path of travel from a fire compartment leads by one or more horizontal exits directly into another fire compartments which has at least one required exit which is not a horizontal exit. Cannot be utilised in some classes or areas of buildings details to be assessed to ensure compliance with specific clause	
	D1.12	Non required stairs	
N/A		May connect 2 levels in a non-sprinkler protected building. Within a sprinkler protected building may serve 3 storeys.	
	D1.13	Number of persons accommodated	
✓		To be in accordance with Table D1.13 of the BCA or count seats.	Based on Toilet numbers a maximum staff population of 10 staff is allowable Students numbers based on the exit widths can be up to 190 students, however due to class size limitation and other factors the numbers will be much less.

Icon	Clause	Reference	Comment
	D1.16	Plant rooms and lift motor rooms: Concessions	
N/A		<p>(a) Where a plant room or lift motor room has a floor area:</p> <p>(i) Not more than 100m² a ladder may be used in lieu of a stairway.</p> <p>(ii) More than 100m² but less than 200m² where two or more points of egress are provided a ladder may be used in lieu of a stairway from all but one of those points.</p> <p>(c) A ladder to the plant room is to comply with AS 1657 and the ladder to the lift motor room is to comply with AS 1735.2.</p>	

Part D2 – Construction of Exits

Icon	Clause	Reference	Comment
	D2.2	Fire isolated stairs	
N/A		Must be in a fire resisting shaft and be constructed of non-combustible materials and if there is local failure not cause structural damage or impair the fire resistance of the shaft.	
	D2.3	Non fire isolated stairs	
N/A		<p>Non fire isolated stairways must be constructed of either:-</p> <p>(a) reinforced or pre stressed concrete</p> <p>(b) 6mm thick steel</p> <p>(c) 44mm thick timber</p>	
	D2.4	Separation of rising and descending stairs flights	
N/A		A required fire isolated stair cannot connect above and below ground flights unless separated by fire and smoke separation.	
	D2.5	Open access ramps and balconies	
N/A		<p>Open access ramp or balcony is provided to meet the requirements of smoke hazard management E2.2a, it must;</p> <ol style="list-style-type: none"> 1. have ventilation openings to the outside air; & 2. not be enclosed on its open sides above height of 1m. 	
	D2.6	Smoke lobbies	
N/A		<p>Smoke lobby required by D1.7 must;</p> <ol style="list-style-type: none"> 1. have a floor area not less than 6sqm; and 2. be separated by walls impervious to smoke; and 3. be fitted with smoke doors; and 4. be pressurised if the exit is required to be. 	

Icon	Clause	Reference	Comment
D2.7 Installations in exits and paths of travel			
CR	(b) No openings to ducts conveying hot products of combustion permitted. (c) Gas or fuel services not permitted in required exits. (d) Electric or services equipment not permitted unless in a non-combustible and smoke sealed enclosure.		Any new installations to achieve compliance and any existing EDB 's or the like are to be upgraded to be within non-combustible enclosures suitably smoke sealed.
D2.8 Enclosure of space beneath stairs			
N/A	(a) in a fire stair no cupboards are permitted under the stair (b) the space beneath the non-fire isolated stairs are not to be enclosed unless in 60/60/60 construction with 60/60/30 fire doors.		
D2.9 Width of stairs			
N/A	When a measurement taken the width is to be measured clear of all obstructions and the stair must extend a minimum 2.0m above nosings. (unless specified elsewhere to require a greater height)		
D2.10 Pedestrian ramps			
CR	Pedestrian ramp to be installed in accordance with AS 1428.1, and not have a gradient steeper than 1:8, and be finished with a non-slip surface.		New Access ramps are proposed to be provided to achieve compliance for access to the building – Disabled Access consultant is to advise on requirements for this item
D2.11 Fire-isolated passageways			
N/A	To attain the same FRL as the fire isolated stair		
D2.12 Roof as open space			
N/A	If an exit discharges to a roof of a building, the roof must; 1. have an FRL 120/120/120; & 2. not have roof lights or other openings within 3m of the path of travel.		
D2.13 Treads and risers			
N/A	(a) minimum 2 risers / maximum 18 in each flight (b) risers 115mm min 190 mm max - going 250mm min 355mm max - 2R+G 550mm min 700mm max. (c) goings and risers to be constant. (d) risers not to permit 125mm sphere to pass through (e) treads to be non slip (h) no stepped quarter landings		
D2.14 Landings			
✓	Maximum gradient not to exceed 1:50 and be a minimum 750 long measured from the inside edge of the landing.		

Icon	Clause	Reference	Comment
	D2.15	Thresholds	
✓		<p>No step or ramp at any point closer to the door than the width of the door leaf.</p> <p>Generally doors opening to outside are able to be provided with a maximum 190mm step or 50mm if Class 9b POPE</p>	
	D2.16	Balustrades	
N/A		<p>A continuous balustrade or barrier must be provided along the side of any roof to which public access is provided, any stairway or ramp, any floor, corridor, hallway, balcony, veranda, mezzanine, access bridge or the like and along any side of any access path to a building if it is not bounded by a wall and the level above the floor or ground surface is more than 4m where it is possible to fall through an open window or 1m in any other case.</p> <p>Note: Frameless glass balustrades are no longer a feasible option to achieve compliance with the BCA – see AS 1288-2006 for details of balustrade to ensure design achieves compliance.</p>	
	D2.17	Handrails	
N/A		Required along one side and on both sides of stairs over 2m in width, 865mm above nosings and be continuous.	
	D2.18	Fixed platforms, walkways, stairways and ladders	
N/A		Treads, risers, handrails and balustrades in plant rooms etc must comply with AS 1657	
	D2.19	Doorways and doors	
CR		<p>Must not be revolving door, roller shutter or tilt door. Can be fitted with a sliding door if it leads directly to open space and can be opened manually under a force of not more than 110N and be fitted with a fail-safe device if the door is power operated.</p>	<p>New works will achieve compliance</p> <p>Most of the doors currently achieve compliance in relation to this measure</p>
	D2.20	Swinging doors	
✓		Must not encroach more than 500mm into the required width of the stair or 100mm when fully open and swing in the direction of travel.	

Icon	Clause	Reference	Comment
	D2.21	Operation of latch	
CR		<p>To be located 900mm to 1100mm above the floor and be openable with a single-handed downward action.</p> <p>Fail safe unlock is permitted as long as linked to the base building fire alarm system.</p> <p>Class 9b or POPE doors if to be secured must be provided with panic bars only (fail safe option does not comply)</p>	<p>New works to achieve compliance</p> <p>Existing two doors are to be upgraded to achieve compliance – unless significant heritage issue and in that case an alternative solution from a fire safety engineer will be required to justify the latching arrangement proposed at the CC stage</p>
	D2.22	Re-entry from fire-isolated exits	
N/A		<p>Every door in a fire stair must not be locked from inside the fire- isolated stairway to prevent re-entry to the storey or room it services for any stair that serves a storey over 25m in height.</p> <p>Specific details of compliance are defined in this clause of the BCA – the doors all must unlock on fire trip, if needed to be locked may be provided with alarm to allow re entry in a non-fire situation</p>	
	D2.23	Signs on doors	
N/A		To fire doors signage required to alert persons that blockage, obstruction or being chocked open is not allowable	

Part D3 – Access for People with Disabilities

Icon	Clause	Reference	Comment
D3.2 Access to building in general			
CA	a) From the boundary to main points of entry b) From a disabled car space c) Other buildings on the allotment d) Through the principal public entrance. Access to and within the building must comply with AS 1428.1 and Part D3 of the BCA.		Disabled Access Consultant to provide requirements
D3.3 Parts to be accessible			
Noted	a) (i) (A) To sanitary compartment: (B) To areas normally used by occupants (excluding plant and service areas) (iii) Every lift to comply with E3.6.		
D3.4 Concessions			
N/A	It is not necessary to provide access for people with disabilities to: a) more than 30% of the public space in Class 6 restaurant, café, bar b) any area if access would be inappropriate due to use.		
D3.5 Car parking			
N/A	Spaces provided as to AS 2890.1 Disabled car spaces must be provided within the carpark at the ratio of 1 disabled car space per 50 /100 spaces.		
D3.6 Signage regarding disabled access			
CA	To be provided at entrance, lifts and sanitary accommodation.		Disabled Access Consultant to provide requirements
D3.7 Hearing augmentation			
N/A	Where an inbuilt amplification system other than an EWIS is provided a hearing augmentation system is to be provided in the following locations:- <ul style="list-style-type: none"> Conference room with a floor area greater than 100m², Judiciary room, Auditorium in a Class 9b building, Ticket office, reception area where the public is screened from the service provider. 		No inbuilt hearing augmentation proposed
D3.8 Tactile indicators			
CR	Required to public stairs and ramps in accordance with AS 1428.4.		Disabled Access Consultant to provide requirements

Section E: Services and Equipment

Part E1 – Fire Fighting Equipment

Icon	Clause	Reference	Comment
E1.3 Hydrants			
CR	a)	System to be provided to serve whole building:- (i) Floor area exceeds 500m ² b) (i) Installed to AS 2419.1-2005 (iii) Pump set to AS 2419.1.	To be upgraded to achieve compliance for the building – Hydraulic Engineer to ensure compliance at CC stage
E1.4 Hose reels			
CR	a)	System to be provided to serve whole building:- (i) Where hydrants installed internally or to serve any fire compartment greater than 500m ² : b) (i) Installed to AS 2441-2005 (iii) Hose to reach every part (iv) (A) Located externally or, (B) Within 4m of exit or, (C) Adjacent to hydrant (not within fire isolated exit).	To be upgraded to achieve compliance for the building – Hydraulic Engineer to ensure compliance at CC stage Will involve new FHR installations within 4m of exit door to outside
E1.5 Sprinklers			
N/R		System may be required to be provided to serve the entire building to AS 2118.1 and Spec E1.5 as applicable, see Table E1.5 for details when required	
E1.6 Portable fire extinguishers			
CR		To be installed to Table E1.6 and AS 2444.	Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
E1.8 Fire control centres			
N/A		A fire control centre facility is required for a building that exceeds 18,000m ² in total floor space or where the building exceeds 25m effective height. A Building that exceeds 50m in height is required to be provided with a dedicated fire control room that complies with Spec E1.8	

Part E2 – Smoke Hazard Management

Icon	Clause	Reference	Comment
E2.2 General requirements			
CR	E2.2a	Automatic smoke detection and alarm system to Spec E2.2a and AS 1670.1-2004	To be installed / upgraded to achieve current compliance
CR	E2.2b	All Class 9b Buildings are required to be provided with automatic shutdown of any mechanical ventilation or air conditioning systems on fire trip.	Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
E2.3 Provision for special hazards			
N/A		Additional smoke hazard management measures may be necessary due to the: a) Special characteristics of the building	

Part E3 – Lift Installations

Icon	Clause	Reference	Comment
E3.2 Stretcher facility in lifts			
N/A	(a)	Must be provided with: (i) at least 1 emergency lift required by E3.4 (ii) where emergency lift is not required, in at least 1 passenger lift in buildings over 12m. (b) Not less than 600mm wide and 2,000mm long x 1,400mm height.	
E3.3 Warning against use of lift in fire			
N/A		Warning signs are required at each lift landing located near every call button in accordance with Figure E3.3.	
E3.4 Emergency lifts			
N/A		Required to buildings over 25m in effective height, complying with AS 1735.2.	
E3.6 Facilities for people with disabilities			
N/A		Where required by D3.3 (a) every lift must be installed to meet requirements of AS 1735.2 and AS 1735.12.	
E3.7 Fire service controls			
N/A		All passenger lift cars require fire service controls in accordance with AS 1735.2	

Part E4 – Emergency Lighting, Exit and Warning Systems

Icon	Clause	Reference	Comment
	E4.2	Emergency lighting	
CR		Required in every path of travel to an exit and any room having a floor area more than 100m ² that does not open to a corridor or space with emergency lighting and any room having a floor area in excess of 300m ² required in every required non fire isolated stair. Emergency signage to be installed to AS 2293.1	Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
	E4.3	Measurement of distance	
CR		Distances other than vertical rise must be measured along the shortest path of travel whether by straight lines, curves or a combination of both.	Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
	E4.4	Design and operation of exit signs	
CR		Every required exit sign must comply with AS 2293.1	Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
	E4.5	Exit signage	
CR		Required above egress doors and doors from an enclosed stair to open space. Directorial signs required to designate paths of travel. Exit signage to be installed to AS 2293.1	Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
	E4.6	Direction signs	
CR		Where an exit is not apparent, exit signs with directional arrows are required. Class 9b POPE must have exit signs external to the building to show the way to the road if not apparent when in the open space.	Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
	E4.7	Class 2, 3 and 4 parts: Exemptions	
Noted		E4.5 does not apply to- 1. Class 2 building if the word "EXIT" is placed on the side of door remote from an exit, 2. An entrance door of a SOU in Class 2, 3 or 4.	

Icon	Clause	Reference	Comment
	E4.8	<i>Design and operation of exit signs</i>	
CR		Every required exit sign must - (a) Comply with AS 2293.1; and (b) Be clearly visible at all times when the building is occupied.	Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.
	E4.9	<i>Sound systems and intercom systems for emergency purposes</i>	
N/A		Sound systems and intercom systems for emergency purposes required to comply with AS 1670.4-2004; 1. Class 9b used as a school with RIS of more than 3, or public Hall/POPE with floor area over 1000m2 or RIS of more than 2.	

Section F: Health and Amenity

Part F1 – General

Icon	Clause	Reference	Comment
	F1.1	Stormwater Drainage	
CR		Stormwater drainage must comply to AS 3500.3.2	New works are to achieve compliance
	F1.5	Roof Covering	
CR		Roof covering must comply with required Australian Standard.	<p>New works are to achieve compliance</p> <p>There are some issues with the existing building, and due to the heritage nature of the building the works are to be upgraded to achieve the most compliant outcome, however full compliance may not be achieved</p>
	F1.6	Sarking	
CR		Sarking used for weather proofing of roofs must comply with AS/NZS 4200.	New works are to achieve compliance
	F1.7	Water Proofing of Wet Areas in Buildings	
CR		Water proofing of wet areas within a building to comply with AS 3740.	New works are to achieve compliance
	F1.9	Damp-proofing	
CR		Damp-proofing where required to be installed in accordance with AS/NZS 2904 or AS 3660.1	<p>New works are to achieve compliance</p> <p>There are some issues with the existing building, and due to the heritage nature of the building the works are to be upgraded to achieve the most compliant outcome, however full compliance may not be achieved</p>
	F1.10	Damp-proofing of Floors on the Ground	
CR		Damp-proofing where required to be installed in accordance with AS 2870	<p>New works are to achieve compliance</p> <p>There are some issues with the existing building, and due to the heritage nature of the building the works are to be upgraded to achieve the most compliant outcome, however full compliance may not be achieved.</p>

Icon	Clause	Reference	Comment
	F1.11	Provision of Floor Wastes	
NA		In a Class 2, 3 or 4 part of a building, the floor of each bathroom and laundry located at any level above a sole-occupancy unit or public space must be graded to permit drainage to a floor waste.	
	F1.12	Sub-floor Ventilation	
CR		The sub-floor space between a suspended floor of a building and the ground must be in accordance with the requirements of this clause.	<p>New works are to achieve compliance</p> <p>There are some issues with the existing building, and due to the heritage nature of the building the works are to be upgraded to achieve the most compliant outcome, however full compliance may not be achieved</p>
	F1.13	Glazed assemblies	
CR		Glazed assemblies in an external wall to comply with AS 2047 requirements for resistance to water penetration	New works are to achieve compliance

Part F2 – Sanitary and Other Facilities

Icon	Clause	Reference	Comment
	F2.1/3	Sanitary facilities in Class 3-9 buildings	
CR		<p>The number of sanitary facilities must be based upon the number of person accommodated calculated in accordance with D1.13</p> <p>See Table F2.3 for details of number of toilets, washbasins and Urinals required.</p>	<p>Staff Facilities (up to 10 staff)</p> <p>1 Disabled Unisex facility required</p> <p>Students</p> <p>Toilet facilities for students are provided on the school grounds, as such provision of toilets in the building for students is not provided nor required –details at CC stage.</p>
	F2.4	Facilities for persons with disabilities	
CR		<p>One wheelchair accessible disabled facility is required within the building. Layout of each facility must comply with AS 1428.1.</p> <p>If more than one facility proposed they must be alternative layouts for left or right handed usage.</p> <p>Doors to disabled toilets are required to be provided with Lift off hinges to the doors irrespective of size, and must be provided with a shelf</p>	<p>1 Unisex Disabled Facility in the Building will achieve compliance –specific design are to be provided at the CC stage</p>
	F2.5	Construction of sanitary compartments	
CR		<p>Where clear space between closet pan and doorway is less than 1.2m, doors must open outwards, slide or be readily removable from outside.</p> <p>Doors to disabled toilets are required to be provided with Lift off hinges to the doors irrespective of distance between pan and doorway</p>	<p>New works are to achieve compliance</p>

Part F3 – Room Sizes

Icon	Clause	Reference	Comment
	F3.1	Height of Rooms	
✓		<p>Room heights to be a minimum of 2.4m and 2.1m in corridors.</p> <p>Class 9b POPE requires ceiling heights of 2.7m if more than 100 persons in the storey or area</p>	

Part F4 – Provision of Natural Light

Icon	Clause	Reference	Comment
	F4.1	Provision of Natural Light	
CR		<p>Class 9b classrooms requires 10% of the floor area to be windows for natural lighting</p>	<p>Required to all classrooms</p> <p>Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.</p> <p>If heritage issues then heritage is to take precedence and windows as existing are satisfactory, however skylights are recommended as an alternative to windows to give the light requirements' (see Sect J for details for skylights)</p>
	F4.4	Artificial Lighting	
CR		<p>Required to all rooms that are frequently occupied, all spaces required to be accessible, all corridors, lobbies, internal stairways, other circulation spaces and paths of egress.</p> <p>Artificial lighting system is to comply with AS 1680.0</p> <p>Note: See also Section J for details of energy efficiency of lighting required.</p>	<p>Design statement (or other means) required from appropriate persons that the new works will comply with this clause at the design stage & also certified on completion of the project.</p>
	F4.5	Ventilation of Rooms	
CR		<p>A mechanical ventilation or air conditioning system complying with AS 1668.2 is required.</p> <p>Note: See also Section J for details of energy efficiency of Ventilation / Mechanical Ventilation/Air-conditioning required.</p>	
	F4.11	Car Parks	
N/A		<p>Every storey of a car park, except an open deck car park, must have a system of ventilation complying with AS/NZS 1668.1 and AS/NZS 1668.2.</p>	

Part F5 – Sound Transmission and Insulation

Icon	Clause	Reference	Comment
	F5.3	Sound Insulation of floors between units	
N/A		A floor separating sole occupancy units must have an R_w (sound reduction index) not less than 45.	
	F5.4	Sound Insulation of walls between units	
N/A		A wall must have an R_w not less than 45 if it separates: (a) sole occupancy units; or (b) a sole occupancy unit from a plant room, lift shaft, stairway, public corridor, hallway or the like.	
	F5.5	Walls between a bathroom, sanitary compartment, laundry or kitchen and a habitable room in adjoining unit	
N/A		Walls must have: (i) an R_w of not less than 50; and (ii) provide a satisfactory level of insulation against impact sound; and (iii) not incorporate a duct which reduces the R_w of the wall to less than 50.	

Section G: Ancillary Provisions

Part G1 – Minor Structures and Components

Icon	Clause	Reference	Comment
	NSW G1.101	Provision for Cleaning of Windows	
N/A		Provision is to be made for the cleaning of windows either within the building or to the OH& S Act 2000 for any windows three (3) or more above the ground.	

Section H: Special Use Buildings

Part NSW H101 – Place of Public Entertainment

Icon	Clause	Reference	Comment
	NSW H101.2	Fire Separation	
N/A		The “Entertainment Venue” is required to be separated from the remainder of the building by construction that achieves an FLR of not less than 60/60/60, and any doors in the separating construction must achieve an Fire rating of -/60/30	
	NSW H101	Stage Size	
N/A		If the stage or performance areas in any of the POPE places / rooms exceed 50m ² in floor area then automatic smoke exhaust would be required directly over the stage area in order to achieve compliance	
	NSW H101.16	Storerooms	
N/A		Storerooms must be separated from other parts of the building by fire rating of not less than 60/60/60 with doors self closing and achieving -/60/30	
	NSW H101.19	Electric Mains Installation	
N/A		The Switchboard containing the main isolation switch must be located in a position that is readily accessible to authorised persons and the fire brigade, and is required to be enclosed in construction achieving an FLR of 60/60/60	
	NSW H101.19.2.3	Circuit Protection & Separate Sub-mains	
N/A		Protection of the final sub circuit originating at a switch board or DB must be by means of a circuit breaker Where a place of public entertainment (POPE) has its main supply in common with that of another part of the building, the POPE must be served by its one and independent sub-main, each such sub main must be protected against fire by protection that achieves protection for 2 hours fire protection	
	NSW H101.20	Lighting Switches / controls	
N/A		Where during normal use the lighting is dimmed or switched off there must be an override switch installed in the theatre area that is accessible by the management/staff to switch on all of the general lighting in the theatre is required	

Section I: Maintenance

Part I1 – Equipment and Safety Installations

Icon	Clause	Reference	Comment
	NSW I1.1	<i>Essential Services Measures</i>	
<i>Noted</i>		Essential fire or other safety measures must be maintained and certified on an ongoing basis in accordance with the provisions of the Environmental Planning & Assessment Regulation 2000.	

Section J: Energy Efficiency

Part J1 to J8 – Building Fabric

Icon	Clause	Reference	Comment
	J1.1	Application of Part	
CA		<p>This part apply to building elements forming an envelope of a Class 2 to 9 building other than –</p> <p>Class 7, 8 or 9b building that does not have a conditioned space or an atrium that is separated by an envelope.</p>	<p>New works are to achieve compliance</p> <p>There are some issues with the existing building, and due to the heritage nature of the building the works are to be upgraded to achieve the most compliant outcome, however full compliance may not be achieved – see compliance section at front of the report</p>
	J1.2	Thermal Construction General	
		<p>Where required, <i>insulation</i> must comply with AS/NZS 4859.1 and be installed so that it:</p> <ul style="list-style-type: none"> Abuts or overlaps adjoining insulation and forms a continuous barrier with ceilings, walls, bulkheads, floors or the like that contribute to the thermal barrier; 	
		<p>Where required, <i>reflective insulation</i> must be installed:</p> <ul style="list-style-type: none"> With the required air space to achieve the R-Value between the reflective side and the cladding. Closely fitted against penetrations, door or window openings and supported by framing members. Each sheet overlapped not less than 50mm or taped together; 	
		<p>Where required, <i>bulk insulation</i> must be installed:</p> <ul style="list-style-type: none"> Maintain its thickness, other than where it crosses roof batten, water pipes, electrical cabling and the like; and in ceiling where there is no bulk insulation or reflective insulation in the wall, overlaps by 50mm 	
	J1.3	Roof and Ceiling Construction	
		<p>A roof or ceiling in Climate Zone 5 is to achieve a Total R-Value in the UPWARD direction of heat flow of not less than:</p> <ul style="list-style-type: none"> 3.2 – for a roof or ceiling generally; 	<p>New works are to achieve compliance</p> <p>Existing parts - The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded of the report</p>

Icon	Clause	Reference	Comment
J1.4 Roof Lights			
N/A		<p>Roof lights that form part of the envelope of a Class 5, 6, 7, 8 or 9 building must satisfy:</p> <p>(a) If the area of the roof light is between 1.5%-10% of the floor area of the room they must comply with Table J1.4.</p> <p>(b) roof light may exceed 10% of the floor area of the room, where -</p> <p>compliance with the natural lighting requirements of Part F4 can only be achieved by the roof light; and the transparent and translucent elements, achieve:</p> <ul style="list-style-type: none"> - an SHGC not more than 0.25; and - total U-Value of not more than 1.3. 	
J1.5 Walls			
CA		<p>External walls within Climate Zone 5 achieve:</p> <ul style="list-style-type: none"> • A Total R-Value of 2.8; or • A surface density of not less than 220kg/m² 	<p>New works are to achieve compliance</p> <p>Existing parts - The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded of the report</p>
J1.6 Floors			
CA		<p>A suspended floor that is part of a buildings envelope to comply with Specification J1.6</p>	<p>The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.</p>

Part J2 – External Glazing

Icon	Clause	Reference	Comment
J2.1 Application of Part			
CA		<p>This part of the BCA does not apply to a Class 7, 8 or 9b building that does not have a conditioned space.</p>	<p>The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.</p>

Icon	Clause	Reference	Comment
	J2.2	<i>Applicable glazing provisions</i>	
CA		Glazing in a Class 5, 7, 8, 9a and 9b building must be designed and installed in accordance with Clause J2.4 of the BCA.	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.

	J2.4	<i>Glazing</i>	
CA		<p>(a) the glazing in each storey of the building facing each orientation must be assessed separately in accordance with (b) and (c);</p> <p>Refer to Glazing Calculator by ABCB to assess compliance with Clause J2.4 (Method 2) of the BCA.</p>	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.

Part J3 – Building Sealing

Icon	Clause	Reference	Comment
	J3.1	<i>Application of Part</i>	
CA		<p>Applies to elements forming the envelope of a class 2-9 building (doors, windows, walls, roof/ceilings etc).</p> <p>Except for buildings in climate 1,2,3 or 5 where the only means of cooling is by an evaporative cooler or</p> <p>A permanent building ventilation opening for safe operation of a gas appliance</p> <p>A class 6, 7, 8 or 9b building that does not have a conditioned space</p> <p>A building or space where the mechanical ventilation provides sufficient pressurisation to prevent infiltration</p>	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.

	J3.2,3,5	<i>Chimneys, Roof lights, exhaust fans</i>	
CA		<p>Chimneys or flues must be provided with a damper or flap that can be closed to seals the chimney or flu when not in use</p> <p>Roof lights must be sealed by a diffuser or shutter system unless required as a building window for light</p> <p>Miscellaneous Exhaust fans must be provided with a damper that self closes when the fan is not in use</p>	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.

Icon	Clause	Reference	Comment
	J3.4	External Windows and Doors	
CA		<p>A seal to restrict air infiltration must be fitted to each edge (top, bottom and sides) of an external door or window or the like when serving a conditioned space or for habitable rooms in climate zones 4,6,7 & 8.</p> <p>Excluding:</p> <ul style="list-style-type: none"> - Windows that comply with AS 2047 - fire doors <p>Roller shutter doors or security doors installed for out of hours security only</p> <p>External louver door, windows or other such openings</p>	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.

Part J5 – Air Condition & Ventilation Systems

Icon	Clause	Reference	Comment
	Part J5	Air Con and Mech Vent system design	
CA		<p>Ductwork for supply and return air must be insulated</p> <p>Design of the system must achieve compliance with all parts of Part J5 of the BCA</p>	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.

Part J6 – Artificial Lighting & Power

Icon	Clause	Reference	Comment
	Part J6.1	Application of part	
CA		This part of the BCA does not apply to a Class 2 or 4 buildings or parts within the Sole occupancy unit/s.	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.
	J6.2	Interior artificial lighting	
CA		The Design Illumination power load must not exceed the sum of the allowances achieved by multiplying the area of the space by the maximum illumination power density in Table J6.2b	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.

Icon	Clause	Reference	Comment
J6.5 Artificial lighting around the perimeter of a building			
CA		<p>Exterior lighting must be controlled by either a daylight sensor or a time switch in accordance with Spec J6 to turn off when natural light is effective or during daylight hours and Total perimeter lighting load that exceeds 100w must –</p> <ul style="list-style-type: none"> - have an average light source efficacy of not less than 60 lumens/W or - be controlled by a motion detector in accordance with Spec J6 	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.
J6.6 Boiling water and chilled water units			
CA		Power supply to these units (Billy units) must be controlled by a time switch that complies with Spec J6	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.

Part J7 – Hot Water Supply

Icon	Clause	Reference	Comment
J7.2 Hot Water Supply			
CA		<p>Hot water supply for food preparation and sanitary purposes must comply with Section 8 of AS/NZS 3500.4</p> <p>Solar systems in climate zones 1,2 and 3 do not need to comply with this requirement</p>	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.

Part J8 – Access for Maintenance

Icon	Clause	Reference	Comment
CA		<p>Access for Maintenance must be provided to all services and components, including</p> <ul style="list-style-type: none"> • Time switches and motion detectors • Room temp thermostats • Plant thermostats such as on boilers or refridge units • Outside air dampers • Reflectors, lens and diffusers of light fittings • Heat transfer equipment • Adjustable or motorised shading devices 	The building does not comply with this clause and is not proposed to be upgraded unless a specific condition of consent is imposed to require it to be upgraded.

Appendix 2

Fire Resistance Provisions

Table 5 – Type C Construction: FRL of Building Elements

Building Element	Class of Building – FRL (in minutes) Structural Adequacy/Integrity/Insulation			
	Class 2, 3 or 4 part	Class 5, 9 or 7 (carpark)	Class 6	Class 7 (other than carpark) or 8
External Wall (including any column and other building element incorporated therein) or other external building element, where the distance from and fire-source feature to which it is exposed is:				
Less than 1.5m	90/90/90	90/90/90	90/90/90	90/90/90
1.5m to less than 3m	-/-/-	60/60/60	60/60/60	60/60/60
3m or more	-/-/-	-/-/-	-/-/-	-/-/-
External Column not incorporated in an external wall, where the distance from any fire source feature to which it is exposed is:				
Less than 1.5m	90/-/-	90/-/-	90/-/-	90/-/-
1.5m to less than 3m	-/-/-	60/-/-	60/-/-	60/-/-
3m or more	-/-/-	-/-/-	-/-/-	-/-/-
Common Walls and Fire Walls:				
	90/90/90	90/90/90	90/90/90	90/90/90
Internal Walls –				
Bounding Public Corridors public lobbies and the like:				
	60/60/60	-/-/-	-/-/-	-/-/-
Between or Bounding Sole Occupancy Units:				
	60/60/60	-/-/-	-/-/-	-/-/-
Bounding a stair if required to be rated:				
	60/60/60	-/-/-	-/-/-	-/-/-
Roofs:	-/-/-	-/-/-	-/-/-	-/-/-

OUR OFFICES

Australia

Adelaide +61 8 8410 4044

Brisbane +61 7 3221 1788

Cairns +61 7 4051 7511

Canberra +61 2 6257 4428

Darwin +61 8 8981 8020

Hobart +61 3 6234 8788

Melbourne +61 3 9933 8800

Perth +61 8 9221 8870

Sunshine Coast +61 7 5479 2005

Sydney +61 2 9956 8822

Townsville +61 7 4721 2788

New Zealand

Auckland +64 9 379 9903

Christchurch +64 3 366 2669

Wellington +64 4 472 7505

OUR SERVICES

Project Management

Cost Management

Building Surveying

Urban Planning

Specification Consulting

Infrastructure Verification Services

Technical Due Diligence

Property Performance Reporting

Make Good Assessments

Certification Services

Sustainability Services

DAVIS LANGDON & SEAH INTERNATIONAL

Arabian Gulf, Bahrain, Botswana, Brunei, China, Croatia, England, France, Germany, Hong Kong, India, Indonesia, Ireland, Italy, Japan, Kazakhstan, Lebanon, Malaysia, Mozambique, Nigeria, Pakistan, Philippines, Qatar, Saudi Arabia, Scotland, Singapore, South Africa, South Korea, Spain, Thailand, The Netherlands, United Arab Emirates, United States of America, Vietnam and Wales

www.davislangdon.com