

PEMULWUY MIXED USE DEVELOPMENT

EVELEIGH STREET, REDFERN STORMWATER CONCEPT PLAN

NOTES

GENERAL

1. THE DRAWINGS SHALL BE READ AS REQUIRED IN CONJUNCTION WITH ARCHITECTURAL DRAWINGS
2. ALL DIMENSIONS ARE IN mm UNO. DO NOT SCALE DRAWINGS, USE FIGURED DIMENSIONS
3. THE PROPOSED WORKS DETAILED SHALL BE CONSTRUCTED TO THE REQUIREMENTS OF COUNCIL, GENERALLY AS DETAILED HEREUNDER
4. ALL EXISTING SERVICES SHALL BE VERIFIED FOR DEPTH AND HORIZONTAL POSITION BY PHYSICAL MEANS PRIOR TO EXCAVATION. ANY DISCREPANCIES SHALL BE BROUGHT TO THE SUPERINTENDENTS ATTENTION

STORMWATER DRAINAGE MATERIALS

5. SELECT FILL SHALL BE MATERIAL OBTAINED FROM EXCAVATION OF THE PIPE TRENCH OR IMPORTED WITH A PARTICLE SIZE FOR ROCK NOT GREATER THAN 75mm OR FOR OTHER THAN ROCK NOT GREATER THAN 150mm
6. IMPORTED FILL SHALL BE EITHER, & GENERALLY CONSIST OF SINGLE SIZED AGGREGATE WITH PARTICLE SIZE NOT GREATER THAN 5mm WRAPPED ALL AROUND WITH GEOTEXTILE FILTER FABRIC OR APPROVED HIGH COMPACTION SAND OR APPROVED CRUSHED ROAD GRAVEL CONFORMING TO RTA FORM 3051 OR SIMILAR
7. CONCRETE SHALL HAVE A SLUM OF 80mm. A MAXIMUM AGGREGATE SIZE OF 20mm & STRENGTH GRADE OF 25mPa (KERBS, EDGE STRIPS & CONCRETE ENCASMENT) & 32mPa ELSEWHERE
8. ALL PIPES & FITTINGS FOR STORMWATER DRAINAGE SHALL BE AS FOLLOWS UNO ON THE DRAWINGS:
 - a) UNPLASTISIZED POLYVINYL CHLORIDE (UPVC) WITH SOLVENT WELDED JOINTS FOR DRAINAGE UP TO 300mm
 - b) FIBRE REINFORCED CEMENT WITH RUBBER RINGS FOR PIPE DIAMETERS GREATER THAN 300mm UNO
 - c) REINFORCED CONCRETE WHERE REQUIRED BY AS3500 FOR EXCESSIVE DEPTH
 - d) INSTALL IN ACCORDANCE WITH AUSTRALIAN STANDARD AS3500 EXCEPT WHERE VARIED BY THE CONTRACT DOCUMENTS
9. ALL INGROUND DRAINAGE PIPEWORK SERVING DOWNPIPES SHALL BE MINIMUM 100mm DIAMETER UNO
10. ALL GRATED DRAINS SHALL BE 225mm UNO WIDTH IN TRAFFICABLE AREAS
11. ALL GUTTERS TO BE SIZED AT CONSTRUCTION CERTIFICATION STAGE

EARTHWORKS AND RESTORATION

12. EXCAVATE TRENCHES & STOCKPILE ALL MATERIAL FOR INSPECTION WITH REGARD TO RE-USE
13. BEDDING MATERIAL SHALL CONSIST OF IMPORTED FILL ONLY. THICKNESS OF BEDDING LAYER SHALL BE 75mm IN O.T.R. & 200mm IN ROCK
14. EMBED ALL PIPES WITH IMPORTED FILL. PROVIDE 200mm SIDE SUPPORT & 150mm OVERLAY ABOVE PIPE CROWN
15. TRENCH FILL ABOVE THE EMBEDMENT ZONE TO THE UNDERSIDE OF THE ROAD PAVEMENT OR FOOTWAY FILL MATERIAL SHALL BE AS FOLLOWS:

UNDER ROADWAY:

TRENCH FILL MATERIAL SHALL CONSIST OF IMPORTED FILL AS SPECIFIED OR EITHER HIGH GRADE COMPACTION SAND OR APPROVED CRUSHED ROAD GRAVEL CONFORMING TO RTA FORM 3051 OR SIMILAR

OTHER THAN ROADWAY:

TRENCH FILL MATERIAL EXCAVATED SHALL CONSIST OF SELECT FILL AS SPECIFIED & SHALL NOT CONTAIN MORE THAN 20% OF STONES OF SIZE BETWEEN 25mm & 150mm AND NONE LARGER THAN 150mm. PRIOR TO USE OF THE EXCAVATED MATERIAL IT SHALL BE INSPECTED & APPROVED BY THE CONSULTANT

16. COMPACT BEDDING, EMBEDMENT & TRENCH FILL MATERIALS AS FOLLOWS:

EMBEDMENT:

FOR GRANULAR FILL MATERIAL (NON-COHESIVE SOILS) EG: COARSE AGGREGATE FILL, HIGH GRADE COMPACTION SAND, THE DENSITY INDEX (ID) SHALL BE NOT LESS THAN 65%

TRENCH FILL:

FOR GRANULAR MATERIAL (NON-COHESIVE SOILS) THE DENSITY INDEX (ID) SHALL BE NOT LESS THAN 85%

FOR NON-GRANULAR FILL MATERIAL (COHESIVE SOILS) THE DRY DENSITY RATIO (RD) SHALL BE NOT LESS THAN 95%

17. RESTORE ALL TRAFFIC AREAS PER STRUCTURAL ENGINEERS DETAILS OR OTHERWISE AS REQUIRED BY COUNCIL
18. FOR ALL SURFACES OTHER THAN IN TRAFFIC AREAS RESTORE DISTURBED SURFACES TO PRE-EXISTING CONDITIONS UNO ON ARCHITECTURAL OR LANDSCAPE ARCHITECTS DRAWINGS & COMPACT AS SPECIFIED

INSTALLATION OF PIPE SYSTEM

19. MINIMUM GRADES FOR GRAVITY STORMWATER DRAINAGE SHALL CONFORM TO AS3500 PART 3 AS FOLLOWS, UNO:
 - 1% FOR 100 DIAMETER
 - 0.5% FOR 150 & 225 DIAMETER
 - 0.4% FOR 300mm DIAMETER
 - 0.35% FOR 375mm DIAMETER

20. PIPES SHALL BE TRUE TO GRADES SHOWN & ALIGNED SO THAT THE CENTRES OF THE INLET PIPES INTERSECT WITH THE CENTRE OF THE OUTLET PIPE AT THE DOWNSTREAM FACE OF THE PIT

21. MINIMUM DEPTH OF COVER SHALL BE:
 - 300mm FOR NON-TRAFFICABLE AREAS
 - 450mm FOR TRAFFICABLE AREAS
 - 600mm FOR HEAVY VEHICLE TRAFFIC AREAS

22. BED ALL PIPES FIRMLY & EVENLY ONTO IMPORTED BEDDING FILL MATERIAL

23. LOCATIONS & FIXING OF PIPEWORK SHALL BE SUBJECT TO CO-ORDINATION WITH OTHER DESIGN DISCIPLINES EG: PENETRATIONS THROUGH CONCRETE ELEMENTS

APPROVALS

24. THE AS CONSTRUCTED WORKS SHALL BE INSPECTED BY COUNCIL BUILDING INSPECTOR OR DESIGN CONSULTANT. MINIMUM 48 HOURS NOTICE SHALL APPLY TO ALL INSPECTIONS
25. COUNCIL ENGINEER TO BE GIVEN 48 HOURS NOTICE OF INTENTION TO COMMENCE CONNECTION TO EXISTING COUNCIL MAIN
26. SUBMIT WORK AS EXECUTED DRAWINGS IN HARD COPY FORMAT. VERIFY ALL CONSTRUCTION WORKS SHOWN
27. CERTIFY THAT THE AS CONSTRUCTED SYSTEM HAS BEEN BUILT IN ACCORDANCE WITH THE APPROVED PLANS ISSUED FOR CONSTRUCTION

LEGEND

EXISTING	PROPOSED	
		STORMWATER MAIN
		SEWER DRAINS OR WASTES
		WASTE LINE
		SUB-SURFACE DRAINS
		AGL GAS MAIN
		NON RETURN VALVE
		BUCKET TRAP
		SILT TRAP
		TRENCH GRATE
		FLOOR WASTE
		EXPANSION JOINT
		CLEAR OUT POINT
		INSPECTION OPENING
		FLUSHING POINT
		JUMP UP TO CLEAR OUT
		ALTERING PIPE
		EXISTING SEWER MAIN HOLE
		STREET FIRE HYDRANT
		OVERLAND FLOW PATH
		SERVICE ID
		SIZE
		T/a

ABBREVIATIONS


eFH	EXISTING FIRE HYDRANT.	MH	MANHOLE.
EX	EXISTING	VR	VERTICAL RISER.
ID	INSPECTION OPENING	JU	JUMP UP.
UPVC	UNPLASTICIZED POLYVINYL CHLORIDE.	AP	ALTERING PIPE.
KO	KERB OUTLET	CO	CLEAR OUT.
FP	FLUSHING POINT	RWT	RAINWATER TANK
RWO	RAIN WATER OUTLET	OSD	ONSITE DETENTION
TG	TRENCH GRATE	SWP	STORMWATER PIT
HP	HIGH PONT		
RWH	RAINWATER HARVEST		
DP	DOWNPIPE		

DRAWING LIST

		SCALE
SC01	COVER SHEET & LEGEND - STORMWATER CONCEPT	N.T.S.
SC02	SITE PLAN - STORMWATER CONCEPT	1:500

A1 SHEET

A		AUTHORITY APPROVAL		15.12.11	NL	NL
No.	REVISION/ISSUE	DATE	BY	CHECKED		



CLIENT	DeiCorp Pty Limited
Shop 5/140-152 New Canterbury Rd Petersham NSW 2049 Phone: (02) 9518 1468 Fax: (02) 9518 1477 Email: fdeir@deicorp.com.au	

ARCHITECT	NORDON · JAGO ARCHITECTS
PO BOX 254 ANNANDALE NSW 2038 T. 02 9 517 2822 F. 02 9 517 2833	

HYDRAULIC CONSULTANT	Neil Lowry & Associates Pty Ltd hydraulic & fire services consultants
Level 3, Suite 1.29 Kiara Road, Miranda NSW 2228 Tel: 61 2 9526 7922 Fax: 61 2 9526 7944 Email: admin@nlaapl.com.au Neil Lowry & Associates Pty Ltd ABN 72 101 872 584	

DRAWN	DESIGNED	CHECKED
KJ	NL	NL

PROJECT				PEMULWUY MIXED USE DEVELOPMENT EVELEIGH STREET REDFERN			
DRAWING				COVER SHEET & LEGEND STORMWATER CONCEPT			
DATE		SCALE		DATE		SCALE	
DEC 11		N.T.S. @ A1		DATE		SCALE	
PROJECT	DWG No.	REV	STATUS				
0577	SC01	A	AUTHORITY APPROVAL				